

ADDENDUM “B”

Request for Quotes RFP #11-0425

911 UPS and GENERATOR

THIS ADDENDUM HEREBY CLARIFIES and MODIFIES the Request for Quotes #11-0425 for the 911 UPS and GENERATOR issued on Friday, April 29, 2011. This Addendum is being issued to notify potential Vendors of a change in the date the RFQ is due as well as to respond to written Vendor questions. The questions and answers are as follows:

**The deadline for RFQ #11-0425 has been extended to
Monday, May 23, 2011 at 11:00 A.M.**

QUESTION: Is there an existing UPS that requires removal before the new UPS is installed?

ANSWER: No.

QUESTION: Are cut sheet or data sheets available for the Eaton UPS and external maintenance by-pass panel?

ANSWER: No.

QUESTION: Has an installation location for the maintenance by-pass panel already been selected?

ANSWER: Yes. It will be located beside the UPS.

QUESTION: Will the UPS be installed on the ground floor or a location above the ground floor?

ANSWER: No. It will be located in the basement.

QUESTION: Are cut sheets available for the Generac generator and automatic transfer switch?

ANSWER: No.

QUESTION: Is the installing contractor required to install a housekeeping pad for the generator?

ANSWER: No.

QUESTION: Will the installing contractor be required to make natural gas connections to the generator?

ANSWER: No.

QUESTION: Are traffic bollards required for the generator?

ANSWER: No.

QUESTION: Will the installing contractor be responsible for landscaping work associated with the generator installation?

ANSWER: Possibly. This will depend on what has to be done.

QUESTION: Is there a specific manufacturer identified for the 200A, 48 circuit electrical panel or will any manufacturer be acceptable?

ANSWER: Randolph County will supply this panel.

QUESTION: Should the installing contractor provide any branch circuit breakers in the 200A, 48 circuit panel? If yes, what size and how many?

ANSWER: No. Randolph County will provide this equipment as well as install it.

QUESTION: Is there a specific AIC rating required for the 200A, 48 circuit electrical panel?

ANSWER: No. Randolph County will provide this as well.

QUESTION: Has an installation location for the 200A electrical panel been selected?

ANSWER: Yes. This will be located in the radio room upstairs.

QUESTION: Does the facility have a loading dock?

ANSWER: Yes.

QUESTION: Can the UPS pass through all doorways, openings, etc. from the unloading area to the permanent location without the removal of doors, etc?

ANSWER: Yes. The opening measurements are 79.5 H x 33.5 W.

QUESTION: Will any of the installation work be required after hours or on the weekend?

ANSWER: Possibly. It will depend on any power down time.

QUESTION: Will an electrical permit be required?

ANSWER: Yes. This permit will be taken out with the Asheboro City.

QUESTION: Will any type of environmental permits be required for the generator installation?

ANSWER: No.

QUESTION: Is it possible to schedule a site visit?

ANSWER: Yes. This will need to be by appointment. Please contact Audrey Alexander at 336-318-6304 or ahalexander@co.randolph.nc.us to set-up an appointment.

QUESTION: Can you provide the UPS and generator installation full address?

ANSWER: Yes. These will be installed at:
Randolph County Emergency Services
152 North Fayetteville Street
Asheboro, NC 27203

QUESTION: Is the installing contractor responsible for the network wiring for the Eaton Power Xpert Gateway UPS card?

ANSWER: Yes.

QUESTION: Are there plans for this project available?

ANSWER: No, unfortunately there are no plans available. However, we do invite you to contact Audrey Alexander at 336-318-6304 or ahalexander@co.randolph.nc.us to schedule a site visit. During the site visit the Fire Marshall or his assistant will guide you through the facility and allow you to examine the building, our current set-up, and give you the opportunity to ask any questions that you might have.